PROSSER LABORATORIES, INC.

P.O. BOX 118 **EFFORT, PA 18330-0118** PHONE: (570) 629-2981

FAX. (570) 620-0695 PA DEP Lab No. 45-289 PA Radon Lab No. 867

EPA and PA Dept.

DAVID C. SCHOLTZ

Located at State Rd. and Rt. 115

of Agriculture Approved

Walker Lake Land Owners Assoc 100 Walker Lake Road Shohola, PA 18458

Analytical Report Date: 07/29/2019

Account No.: 003009

P.O.:

PWSID#:

Attn.

Sample #

1907-02094-001

Date Received:

07/25/2019

Date Sampled:

07/25/2019

Time Received:

15:41

Time Sampled:

11.43

Sample Type: EP Location ID: GRAB

Sampled By:

C.Rush Water

Location:

Clubhouse Beach - center

Test Name

Matrix:

Results/Units

RL

MCL

On-Test Date

On-Test Tech **Time**

End Date End Method Time

E.Coli

<3 EST. CFU/100 ml

7/25/19 17:31

Initials

LK

7/26/19

17:52 SM20th - 9213 D

Sample #

Date Sampled:

1907-02094-002

Water

Date Received:

07/25/2019

07/25/2019

Time Received: Sample Type:

15:41 **GRAB**

11:31 Time Sampled:

EP Location ID:

Sampled By: C.Rush Location:

Swezy Beach - center

Test Name

Matrix:

Results/Units

RL

MCL

On-Test

On-Test Tech

End

End

Method

E.Coli

<u>Date</u>

<u>Time</u>

<u>Initials</u> Date Time

20 EST. CFU/100 ml

7/25/19

17:31

LK 7/26/19 17:52 SM20th - 9213 D

Pa. Dept of Health -BATHING BEACH WATER QUALITY STANDARDS:

E. Coli bacteria shall not exceed 235 cfu per 100 mls of water for an individual sample.

E. Coli. bacteria shall not exceed a geometric average of 126 per 100 mls of water in any 30 day period.

DEFINITIONS:

RL = Minimum Reporting Limit ND = Not Detected < = Less than value stated > = Greater than value stated

David C. Scholtz Laboratory Director